

File: WGN/07/0162/1

Report 07.364

Environment Committee

Minute extract from meeting held on 21 June 2007

Pauatahanui School: objection to consent conditions

Resolved

That the Committee:

1. *Receives the report.*
2. *Notes the contents.*
3. *Substitutes the following conditions in resource consent WGN 070162 with the negotiated changes*

Old condition

2. *The discharge shall be only wastewater of domestic origin as described in the consent application and the maximum discharge of wastewater to the disposal area shall not exceed 5,100 litres of treated wastewater per day.*

20. *The consent holder shall ensure that the quality of the effluent discharge does not exceed the following parameters:*

- a) *BOD5 – 15 mg/l*
- b) *Faecal Coliforms – 10,000 cfu/100ml*
- c) *Total Suspended solids – 15 mg/l*

New condition after negotiation

2. *The discharge shall be only wastewater of domestic origin as described in the consent application and the maximum discharge of wastewater to the disposal area shall not exceed 5,100 litres of treated wastewater per day (**calculated on a weekly average**).*

20. *The consent holder shall ensure that the quality of the effluent discharge does not exceed the following parameters:*

- a) *BOD5 – **45** mg/l*
- b) *Faecal Coliforms – **100,000** cfu/100ml*
- c) *Total Suspended solids – **45** mg/l*